Settings › Integrations › Modbus TCP Server › Available services

See the Settings → VRM → VRM device instances menu to change the Modbus-TCP unit IDs.

BMS16S200A-SP112
com.victronenergy.battery | Unit ID: 225

MPPT 450/100
com.victronenergy.solarcharger | Unit ID: 100

com.victronenergy.system
com.victronenergy.system | Unit ID: 100

VM-3P75CT HQ2543ZXWJK
com.victronenergy.grid | Unit ID: 100

RS6k
com.victronenergy.multi | Unit ID: 100

Bilge pump

Settings › Integrations › Modbus TCP Server › Available services

AC system (0)
com.victronenergy.acsystem | Unit ID: 100

GX Device
com.victronenergy.platform | Unit ID: 100

Opportunity Loads
com.victronenergy.opportunityloads | Unit ID: 100

com.victronenergy.shelly
com.victronenergy.shelly | Unit ID: 100

com.victronenergy.switch
com.victronenergy.switch | Unit ID: 50

Fronius Symo Advanced 15.0-3-M
com.victronenergy.pvinverter | Unit ID: 20